



mdc |

Where networks
connect on the border

Facility Specifications

MDC LAREDO . LDO 1

We interconnect your
business with top providers
under a secure and reliable
environment with 24/7
customer service.

Site Data Sheet . v02



Location

MDC Laredo

13619 Cabezut Drive, Unitec Industrial Park.

Laredo TX 78045, USA.

Phone US: +1 (956) 429.3400

Phone Mexico: 800.681.8063

Email: sales@mdccdatacenters.com



Service level agreement

Historic uptime: 99.982%

Facility Standard or Compliance: Tier III

Power availability: 99.982%

Temperature and Humidity availability: 99.982%



Power & cooling

Electrical capacity: 650 Kw

Battery Backup: 20 min

Utility Feeders: 1

Utility Voltage: 480 Volts

Emergency Power Plant: 1000 Kw

Power autonomy: 48 hrs with full tank before first diesel load

Generator Redundancy: N

Cooling: N+1

Cooling Function: 27 °C (80.6 °F), 18 °C (64.4 °F)

Economizers: Direct Fresh Air downflow



Security

Physical: AC-0a (CPD) y AC-3 based on Tier III. Perimeter Barrier

Electronic: Yes



Building

Construction Type: Concrete

Building Type: 1-story building

Seismic Zone: No

Raised floor: 2500 lbs

MDC Constructed: No

Year constructed (DC and building): DC 2018

Leased or owned building: Leased



Fire protection

Fire Suppression: FM200 and CO2

Smoke Detectors: Yes



Interconnection

Fiber Entrance: 2 active entry points

Crossings: No



Amenities

Parking: Free

Loading dock: No

Temporary storage areas: No